

April 5, 2011

Mr. Dick Gaddini
4745 Main Street, Suite 102
Lisle, IL 60532

**RE: Eyes to the Sky Festival
Park District Parks**

Dear Mr. Dick Gaddini

In order to continue the high standard of electrical safety at the festival, the village requests that the following items be addressed.

- The use of portable generators will require all GFCIs on their portable power distribution panels. Please advise your vendor of requirement.
- All extension cords will be GFCI protected, unless it is a dedicated circuit, then it must be a twist-lock. All cords shall be listed for at least "hard usage".
- Use of halogen-type lamps will require a clearance of 12 inches from tent fabric or combustible materials. The luminaire shall have lamp breakage protection.
- The metal tent frames shall be bonded to an equipment ground to the electrical system with at least a #6 copper conductor. The permanent electrical and generator electrical systems will be bonded with an electrical equipment ground of at least a #6 copper conductor.
- Any pools or spas on exhibit will comply with NEC Article 680.
- Carnivals and concessions will comply with NEC Article 525.
- Park District---Need to repair damaged permanent power boxes in food vendor area. The first box farthest south in food vendor area, on inner drive needs to be repaired. There are burn marks around the bushing. Examine all boxes and perform necessary repairs.
- Park District---Please advise your carnival vendor that they are responsible for their contract vendors with regards to electrical safety compliance.

Mayor

Joseph J. Broda

Trustees

Mark Boyle

Cathryn Cawiezel

Lee LaFond

Ken Modaff

Joe Schmitt

Ed Young

Village Clerk

Timothy J. Seeden

Business Office/General

630-271-4100

630-271-4104 Fax

630-271-4142 TDD

Community Development

630-271-4150

Economic Development

630-271-4148

Police Administration

630-271-4200

Public Works

Administration/Engineering

630-271-4170

Operations

630-271-4180